



ISSN NO. 2320-5407

Journal homepage: <http://www.journalijar.com>

INTERNATIONAL JOURNAL
OF ADVANCED RESEARCH

RESEARCH ARTICLE

Voltage Stability analysis of Smart Grid and application of FACTS controller a review paper

RAJKUMARI PANDEY

Manuscript Info

Manuscript History:

Received: 15 February 2015
Final Accepted: 22 March 2015
Published Online: April 2015

Key words:

voltage stability, voltage collapse,
voltage stability index, smart grid,
synchrophasor technology,
FACTS controller

Abstract

Interconnected power systems always operate close to stability limits. Increased penetrations of renewable resources have made the situation worst. A small disturbance to these stretched stability limits may lead to voltage collapse. Thus it is indeed important to develop understanding of the phenomenon through reviewing various case studies in literature. This paper explore the initial review on understanding the voltage collapse phenomena, identification of weak nodes, Synchrophasor technology based voltage collapse detection and control.

*Corresponding Author

RAJKUMARI PANDEY

Copy Right, IJAR, 2015., All rights reserved

INTRODUCTION

The rapid growth of power systems have been witnessed worldwide by engineers, utilities, stakeholders and customers. With increasing energy demands, power system is expanding to accommodate the rapid load growths by introducing micro and small renewable resource based generation plants, constructing new power plants, transmission lines, substations, and control devices. The introduction of the deregulation and restructuring has changed the shape of electric power industry [1].

When a system is undergoing to the situation of voltage instability, the voltage decline within minutes dramatic, generally monotonic, following a disturbance. When this decrease is too pronounced, the system integrity is endangered mainly due to protecting devices that trip generation, transmission, or load equipment. This degradation process may eventually lead to a blackout in the form of a voltage collapse [1], [2].

As a result, several blackouts directly related to voltage collapse have been occurred dealing with which is a very costlier affair, and still a threat to power system stability and security. Some well-known incidents of blackout recorded are;

1. December 4 2014 Detroit US
2. July 31 2012 Northern grid in India
3. July 30 2012 Northern grid in India
4. Nov. 10, 2009 in Itapúa Paraguay-Brazil
5. January-February 2008: in the central Chinese city of Changzhou
6. Aug. 18, 2005: in Indonesia

Northern grid collapse in India on 30 and 31 July 2014 affected about 620 million people [3]. Series of events was responsible for grid failure and the major reason is voltage collapse due to contingency.

Voltage stability is one of the concern area to power engineers in power systems. By connecting adjustable series and shunt compensation maximum transfer capabilities of power network can be enhanced [1]. Such compensation injects reactive VAR to the nodes consequently maintain the voltage magnitude in the nodes close to the nominal values, besides, to reduce line currents and therefore the total system losses [2]. With advent of advancement in power electronic devices named Flexible AC Transmission Systems (FACTS), control of magnitude of voltage in power system with proper control become much easier. Fast advances in computer analysis of power systems have enabled appearance of extensive knowledge related to general power system control and stability. Voltage stability has always been a topic of attraction to power engineers, scientist and researchers. A lot of work has been done and still going on, resulting in number of IEEE standards [3], [4] and books [5]-[8] cover modelling issues in depth. Some of them directly concern the voltage stability problem [9], [10]. Useful definitions of terms related to stability are provided within several taxonomies in [11]-[13].

The increased application of communication and information technology in the field of power system has transformed the world of power engineers in the name of smart grid. The development of Phasor Measurement Unit (PMU) technology [11], [12], in late 1980's, together with advances in computational facilities, networking infrastructure and communications, is a fast growing field of research and lot of work is going on in modernization of power system. Voltage stability has been identified as one area where PMU-enhanced functions could prove useful to prevent system blackouts and the associated social and economic losses [10], [13].

VOLTAGE STABILITY PHENOMENON IN POWER SYSTEM

Definition

“Voltage stability is the ability of a power system to maintain steady acceptable voltages at all buses in the system under normal operating conditions and after being subjected to a disturbance”[1].

Simply stated, voltage instability is linked to the inability of the combined generation-transmission system to provide the power requested by loads, as a result of equipment outages and limitations of reactive power generation [14].

Major reasons for voltage stability problems in power system.

In recent years major black outs around the world has been reported due to voltage instability.

Reasons for the problems of voltage stability in power system are as follows;

- Large load or large disturbance in a heavily stressed power system.
- Large disturbance between generation and load
- Unfavorable load characteristics
- Large distance between Voltage sources and load centers.
- Low voltage profile.
- In sufficient load reactive compensation.
- Action of ULTC during low voltage conditions and.
- Poor coordination between various control and protective systems.
- High reactive power consumption at heavy loads
- Unsuitable locations of FACTS controllers [3][4].

Classifications of voltage stability

The classification of voltage stability can be done in o two broad categories; [1]

1. Large-disturbance voltage stability

It is define as the ability of the power system to maintain stable voltages for large disturbances such as such as system faults, loss of load, or loss of generation. Large disturbance voltage stability may be further subdivided into two types

- a) Transient stability
- b) Long term stability

2. Small-disturbance (Small signal) voltage stability

Small disturbance voltage stability is concerned with a system's ability to control voltages following small perturbations, such as gradual change in load, this types of stability can be studied with steady-state approaches that use linearization of the system dynamic equations at a given operating point

Factors Affecting voltage instability and collapse

The main factor causing instability is the inability of the power system to meet the demand for reactive power.

i. Transient voltage instability

Under low voltage condition the electrical torque of an induction motor is not adequate to meet the required mechanical torque due to this effect the induction motor may not regain the original speed and continue to decelerate leading to stalling of motors which intern aggravates the low voltage problem. This phenomenon is called transient voltage instability. Transient voltage instability is also associated with HVDC links, particularly inverter terminals connected to AC systems with low short circuit capacity [2] [5] [6].

ii. Long term voltage instability

On-load tap-changing transformers and distribution voltage regulations act within a time frame of tens of seconds to tens of minutes to regulate the load a voltage is termed as long term voltage instability. An important factor in long term voltage stability is the current limiting generator [2] [7].

smart grid

Smart grid is a step ahead in terms of technology from existing power system. The infrastructure is same but it aims to modernize the operation and components of existing systems. It incorporates the principle of communication and information technology resulting in more sensible and reliable electric grid. The Synchrophasor technology is the basic building block of a smart-grid which include assets, sensors used to monitor those assets, the control logic that realizes the desired operational status and finally communication among those blocks. Synchrophasor technology can help deliver better real-time tools that enhance system operator's situational awareness [15]. A Synchrophasor system - with wide deployment of phasor measurement units and dedicated high-speed communications which collects and deliver time synchronized high-speed grid condition data, along with analytics and other advanced on-line dynamic security assessment and control applications -- will improve real-time situational awareness and decision support tools to enhance system reliability. Distribution management systems (DMS) are considered the control logic for operation and control of the smart-grid. DMS is at the middle of the smart grid. It actually transforms the traditional grid into smart grid [16]. A lot of research work is going on for synchrophasor assisted voltage stability analysis.[17]-[30].

[17] Presents the fundamental concept of smart grid and its various applications to power system stability study. Various case studies has also been discussed applying smart grid concept.[18] discussed concept of wide area monitoring in voltage stability analysis. A scheme based on wide area monitoring protection and control (WAMPC) also presented. Voltage stability studies are now assisted by wide area monitoring system based on synchrophasor technology are now more accurate efficient and robust. [19]-25]




Fig-1 conceptual model of smart grid

[26] presents a comparative analysis of Synchrophasor Based Voltage Stability Index. and PQVSI. Voltage collapse proximity index can be calculated by using voltage phasors from PMUs. Voltage phasors have accurate data to detect voltage stability margin [18-27].

OVERVIEW OF FACTS CONTROLLERS

Reactive power unbalance creates the problems like voltage deviation during load changes and power transfer limitation. These problems may have a great impact on reliability and security of power supply. Fast and high performance power electronic devices may be a solution to such problems. FACTS controller are power electronics based reactive power controller. They are high power level converter used at high voltages.:[32]

The first FACTS installation was at the C. J. Slatt Substation near [Arlington, Oregon](#). This is a 500 kV, 3-phase 60 Hz substation, and was developed by EPRI, the Bonneville Power Administration and General Electric Company. [33]

Types of Var Sources

System components which generate need for compensation

- Inductances in electrical machines, transmission lines, transformers, reactors.
- Capacitances in transmission lines, cables

Components which provide required compensation

- Mechanically switched reactors and capacitors
- Synchronous condensers
- Thyristor controlled shunt and series compensation
- Converter controlled shunt and series compensation.

Basic types of FACTS controller

Basic Types of FACTS controllers

- **Shunt controllers**
- **Series controllers**
- **Combined shunt-series controllers**
- **Combined series-series**

The shunt controllers are applied to control voltage at and around the operating point by injecting reactive current. Series controllers are applied to improving

voltage profile in a cost effective way were voltage fluctuations are large. However the series controllers are several times more powerful than the shunt controllers.

The combined controllers provide the best of both i.e. an effective power/current flow and line voltage.

A lot of research work has been reported till date, analyzing the effect of FACTS controller on power system stability. [33] presents the effect of series and shunt compensation in increasing the maximum transfer capabilities of power network. [34] Dealing with voltage stability, FACTS controllers injects reactive power to maintain the voltage

magnitude in the nodes close to the normal operating limits, besides, reducing line currents and therefore the total system losses. In general form, system wise aspects are related either to the improvements of security and economics [35]-[50] or to the enhancements of transmission network capability [51]-[56].

Different FACTS devices have various application in power system operation.

Operating Problems	Corrective action	FACTS controller
Low voltage at heavy load	Supply reactive power	STATCOM SVC
High voltage at low load	Absorb Reactive power	STATCOM SVC TCR
High voltage following an outage	Absorb Reactive power	STATCOM SVC TCR
Low voltage following an outage	Supply reactive power	STATCOM, SVC
Transmission circuit over load	Reduce over load	TCSC UPFC SSSC IPC PS
Tripping of parallel load	Limit circuit loading	TCSC UPFC SSSC IPC PS
Parallel line load sharing	Adjust series reactance	TCSC UPFC SSSC IPC PS
Post fault load sharing	Use thermal limit action	TCSC UPFC SSSC IPC PS
Power flow direction reversal	Adjust phase angle	UPFC SSSC IPC PS

Tab 1 Different roles of various FACTs devices

CONCLUSION

This paper presents the review on concept of voltage stability. various taxonomy and definition of voltage stability and voltage collapse. Classification of voltage stability, major reasons for voltage stability problems in power system, Factors Affecting voltage instability and collapse. Also review on transformation of existing grid into smart grid and also concept of Synchrophasor technology has been presented. Basic concepts of FACTS controller and their application under various operating condition of power system has also been surveyed in this paper.

References

- [1] Prabha kundur, Power System Stability and Control, Tata.
- [2] Sandeep Gupta, Prof. R. K. Tripathi, and Rishabh Dev Shukla, "Voltage Stability Improvement in Power Systems using Facts Controllers: State-of-the-Art Review," 978-1-4244-8542-0/10/\$26.00 ©2010 IEEE
- [3] Helen Pidd (31 July 2012). "India blackouts leave 700 million without power". The Guardian. Retrieved 31 July 2012

- [4] Power Systems Engineering Research Center, Resources for Understanding the Moscow Blackout of 2005. /MoscowBlackout.htm
- [5] Report on failure inquiry in UES of Russia that took place at May 25,2005 – in Russian [Online]. Available: Available online at: http://www.mosenergo.ru/download/r410_account.zip.
- [6] Vournas, C.D., Nikolaidis, V.C. and Tassoulis, A., "Experience from the Athens blackout of July 12, 2004 " IEEE Russia Power Tech, St. Petersburg,2005
- [7] Doorman, G. K., Uhlen,K. ;Huse, E. S. , "Vulnerability analysis of the Nordic power system," IEEE Trans. on Power Systems, vol. 21, pp. 402 - 410, 2006.
- [8] U.S-Canada Power System Outage Task Force, "Final report on the august 14, 2003 blackout in the United States and Canada: causes and recommendations," April 2004.
- [9] OFGEM, "Report on support investigations into recent blackouts in London and west midlands,main report," February 2004.
- [10] A. G. Phadke, J. S. Thorp, Synchronized Phasor Measurements and Their Applications, Springer, 2008
- [11] A. G. Phadke, "Synchronized Phasor Measurements in Power Systems," IEEE Computer Applications in Power, Vol. 6, No. 2, pp. 10-15, Apr. 1993.8
- [12] D. Novosel, V. Madani, B. Bhargava, K. Vu, J. Cole, "Dawn of the Grid Synchronization: Benefits, Practical Applications, and Deployment Strategies for Wide Area Monitoring, Protection, and Control," IEEE Power and Energy Magazine, pp. 49-60, Jan./Feb. 2008
- [13] M. Glavic, T. Van Cutsem, "Wide-Area Detection of Voltage Instability From Synchronized Phasor Measurements. Part II: Simulation Results," IEEE Trans. Power Syst., Vol. 24, No. 3, pp. 1417-1425, Aug. 2009
- [14] T. Van Cutsem and C. Vournas, Voltage Stability of Electric Power Systems. New York: Springer, 1998, previously.
- [15] J A. Bose, "Smart Transmission Grid Applications and Their Supporting Infrastructure," IEEE Transactions on Smart Grid, vol. 1, no. 1, pp. 11–19, June 2010
- [16] usa.siemens.com/smartgrid.
- [17] V. Terzija, G. Valverde, D. Cai, P. Regulski, V. Madani, J. Fitch, S. Skok, M. Begovic, and A. Phadke, "Wide-Area Monitoring, Protection, and Control of Future Electric Power Networks," Proceedings of the IEEE, vol. 99, no. 1, pp. 80 –93, jan. 2011.
- [18] Mohamed E. El-hawary, "The Smart Grid—State-of-the-art and Future Trends," Electric Power Components and Systems, 42(3–4):239–250, 2014.
- [19] Lesnanto M. Putranto,Naebboon Hoonchareon, "Wide Area Monitoring System Implementation in Securing Voltage Stability based on Phasor Measurement Unit Data," 978-1-4799-0545-4/13/\$31.00 2013 IEEE
- [20] Mohamed Najeh Lakhoua and Mohamed Kamel Jbira, "Project Management Phases of a SCADA System for Automation of Electrical Distribution Networks". IJCSI International Journal of Computer Science Issues, Vol. 9, Issue 2, No 2, March 2012.
- [21] [6] W. Pimjaipong, L.Surapongpun, "Wide Area Monitoring System – Planning, Strategy and Implementation in Thailand's Power Grid," Sept.3-5, 2013, China AORC-B-3-0002 CIGRE-AORC 2013.
- [22] Rujiroj Leelaruji, Luigi Vanfretti, and M. Shoaib Almas, "Voltage Stability Monitoring using Sensitivities Computed from Synchronized Phasor Measurement Data," IEEE PES General Meeting 2012, San Diego, CA
- [23] Bindeshwar Singh, N.K. Sharma , A.N. Tiwari , K.S. Verma, and S.N. Singh "Applications of phasor measurement units (PMUs) in electric power system networks incorporated with FACTS controllers". International Journal of Engineering, Science and Technology Vol. 3, No. 3, 2011, pp.
- [24] F.A. Althowibi ,M.W. Mustafa, "Power System Voltage Stability: Indications, Allocations and Voltage Collapse Predictions," IJAREEIE july 2013.
- [25] Pathirikkat, G., Reddy, M. J. B., and Mohanta, D., "stability concerns in smart grid with emerging renewable energy technologies," Elect. Power Compon. Syst., Vol. 42, No. 3–4, pp. 418–425, 2014
- [26] A. G. Phadke, J. S. Thorp, R. F. Nuqui, and M. Zhou, "Recent developments in state estimation with phasor measurements,"Proc. IEEE Power Syst. Conf. Expo., 2008, DOI: 10.1109/PSCE.2009.4839954.

- [27] A. G. Phadke and J. S. Thorp, Synchronized Phasor Measurements and Their Applications. New York: Springer, 2008.
- [28] V. Ajjarapu, "Computational Techniques for Voltage Stability Assessment and Control". New York: Springer, 2006.
- [29] Larsson, M., Rehtanz, C., and Bertsch, J., "Real-time Voltage Stability Assessment for Transmission Corridors, Proceedings of IFAC Power Plants and Power Systems Control - 301 - Conference", Seoul, Korea, 2003.
- [30] Christian Rehtanz, Joachim Bertsch, "Wide Area Measurement and Protection System for Emergency Voltage Stability Control", IEEE proceeding 2002.
- [31] Christian Rehtanz, Joachim Bertsch, "A new wide area protection system", IEEE Proceeding 2001.
- [32] H. K. Tyll, SM IEEE, "FACTS Technology for Reactive Power Compensation and System Control", IEEE/PES panel session on FACTS, Nov 8-11, 04, Sao Paulo.
- [33] C. A. Canizares and Z. T. Faur, "Analysis of SVC and TCSC Controllers in Voltage Collapse," IEEE Trans. on Power Systems, Vol 14, No. 1, pp.1-8. Feb. 1999.
- [34] T. V. Cutsem and C. Vournas, Voltage Stability of Electric Power System, Kluwer Academic Publisher, 1998.
- [35] Begović M., Mills R., "Load identification and voltage stability monitoring," IEEE Trans. Power Systems, vol. 10, no. 1, February 1995, pp. 109-116
- [36] Dwyer A., Nielsen R., Stangl J., "Load to voltage dependency tests at B. C. Hydro," IEEE Trans. Power Systems, vol. 10, no. 2, May 1995, pp. 709-715
- [37] Hajagos L., Danai B., "Laboratory measurements and models of modern loads and their effect on voltage stability studies," IEEE Trans. Power Systems, vol. 13, no. 2, May 1998, pp. 584-592
- [38] Xu W., Vaahedi E., Mansour Y., Tamby J., "Voltage stability load parameter determination from field tests on B.C. Hydro's system," IEEE Trans. Power Systems, vol. 12, no. 3, August 1997, pp. 1290-1297
- [39] N.G. Hingorani, L. Gyugyi, Understanding FACTS, Concepts and Technology of Flexible AC Transmission systems, IEEE Press 2000.
- [40] Y. H. Song and A. T. Johns, Flexible AC Transmission System (FACTS), IEE Power and Energy Series 30, 1999.
- [41] IEEE Power Engineering Society, FACTS Overview. IEEE Special Publication 95TP108, 1995
- [42] IEEE Power Engineering Society, FACTS Applications. IEEE Special Publication 96TP116-0, 1996
- [43] CIGRE Task Force 14-27, Unified Power Flow Controller. CIGRE Technical Brochure, 1998.
- [44] R. M. Mathur and R. S. Basati, Thyristor-Based FACTS Controllers for Electrical Transmission Systems. IEEE Press Series in Power Engineering, 2002.
- [45] Yong Hua Song and Allan T. Johns, Flexible AC Transmission Systems (FACTS). London, UK: IEE Press, 1999.
- [46] Edris A., "FACTS technology development: an update," IEEE Power Engineering Review, vol. 20, no. 3, March 2000, pp. 4-9
- [47] Edris A.A., "Challenges and benefits in developing and applying FACTS technology in the USA," Proceedings of the IEEE Power Tech'99 Conference - BPT'99, Budapest, Hungary, August 1999, paper BPT99-376-44
- [48] Hingorani N., "Flexible AC transmission ," IEEE Spectrum, vol. 30, no. 4, April 1993, pp. 40-45
- [49] Hingorani N., "High power electronics and Flexible AC Transmission System," IEEE Power Engineering Review, July 1988, pp. 3-4
- [50] Hingorani N., "Power electronics in AC power transmission systems," Proceedings of the CIGRÉ Session - Panel 1, P1-00, Paris, France, 1996
- [51] Le Du A., Tontini G., Winfield M., "Which FACTS equipment for which need? Identification of the technology developments to meet the needs of Electricité de France (EDF), Ente per l'Energia Elettrica (ENEL) and National Grid Company (NGC)," Proceedings of the CIGRÉ Joint Session 14/37/38 - Technology and benefits of Flexible AC Transmission Systems, 14/37/38-08, Paris, France, 1992
- [52] Sekine Y., Takahashi K., Hayashi T., "Application of power electronics technologies to the 21st century's bulk power transmission in Japan," Electrical Power & Energy Systems, vol. 17, no. 3, June 1995, pp. 181- 194
- [53] Stahlkopf K., Budney W., Renz B., Cerdan J., Humphries M., "Stretching transmission capacity by technology deployment," IEEE Power Engineering Review, vol. 16, no. 11, November 1996, pp. 4-12

- [54] Stahlkopf K., Wilhelm M., "Tighter controls for busier systems," IEEE Spectrum, vol. 34, no. 4, April 1997, pp. 48-52 [40] Zaborszky J., "On the road towards FACTS," Electrical Power & Energy Systems, vol. 17, no. 3, June 1995, pp. 165-172
- [55] Hitzeroth H.V., Braisch D., Herold G., Povh D., "Compensation, stability and losses in the presence of wheeling transactions with use of FACTS devices," Proceedings of the IEEE Power Tech'99 Conference - BPT'99, Budapest, Hungary, August 1999, paper BPT99-397-12
- [56] Zadeh K., Meyer R., Cauley G., "Practices and new concepts in power system control," IEEE Trans. Power Systems, vol. 11, no. 1, February 1996, pp. 3-10