Journal Homepage: -www.journalijar.com

INTERNATIONAL JOURNAL OF ADVANCED RESEARCH (IJAR)

Article DOI:10.21474/IJAR01/24488
DOI URL: http://dx.doi.org/10.21474/IJAR01/24488

RESEARCH ARTICLE

DIGITAL MODERNIZATION OF GAS TURBINE CONTROL SYSTEMS FOR IMPROVING RELIABILITY AND OPERATIONAL PERFORMANCE IN OIL AND GAS PIPELINE INFRASTRUCTURE

Bilal Ahmed

Manuscript Info

Manuscript History
Received: 18 August 2026
Final Accepted: 20 September 2026
Published: October 2026

Abstract

Gas turbine driven compressor stations are indispensable to long distance oil and gas transmission, yet aging control platforms can restrict reliability, observability, and operational flexibility. This review evaluates how digital modernization of turbine governing, machinery protection, supervisory control, and condition monitoring can improve station performance without weakening safety functions. Thirty peer reviewed studies published between 2021 and 2025 were selected through a transparent, topic focused search of journal and publisher records, with digital object identifiers checked against discoverable publication pages.Evidence was synthesized across control architecture, fault diagnosis, digital twins, compressor interaction, cyber resilience, and maintenance planning. The reviewed work indicates that improved instrumentation and context aware diagnostics can expose degradation earlier, while constrained supervisory optimization can stabilize transitions and reduce avoidable compression energy. However, predictive accuracy does not necessarily imply useful fault sensitivity, and simulation findings rarely demonstrate equivalent benefits in continuous pipeline service. A layered modernization framework is developed that retains independent protective functions, validates signal quality, limits optimization authority, and measures outcomes against operational baselines. Priority research needs include cross asset validation,uncertainty aware decisions,integrated turbine compres sor tests, and longitudinal reliability evidence. The resulting framework offers a practical basis for staged upgrading of pipeline compression assets while avoiding unsupported claims of automatic reliability gains.

"© 2026 by the Author(s). Published by IJAR under CC BY 4.0. Unrestricted use allowed with credit to the author."

Introduction:-

Introduction and problem definition:-

Long distance transmission networks depend on compressor stations to recover pressure lost to friction and changing throughput. In many installations, a gas turbine supplies shaft power to a centrifugal compressor, making turbine speed, fuel delivery, inlet conditions, compressor surge margin, and downstream pressure inseparable operating concerns. A disturbance that appears minor within the turbine governor may alter compressor head or recirculation demand; conversely, a sudden pipeline load change can force the turbine across thermal or acceleration constraints.

Corresponding Author:- Bilal Ahmed

Reliability therefore belongs to the coupled station, not to either machine alone. Pipeline optimisation studies increasingly model these interactions explicitly, although their assumptions often simplify unit level transients (Bu et al., 2024; Chen et al., 2022).Modernisation is frequently presented as replacement of obsolete control hardware with networked processors and visual interfaces. That interpretation is incomplete. A useful upgrade must preserve deterministic governing, permissives, independent trips, anti surge response, operator situational awareness, and recoverability after communications failure. It must also convert accumulated sensor histories into decision quality evidence, rather than merely multiplying alarms. Research on industrial turbine fault detection demonstrates that sophisticated classifiers can expose nonlinear faults, yet successful prediction depends strongly on operating regime, instrument integrity, and the distinction between benign transients and developing damage (Liu et al., 2024; Sarwar et al., 2024).

The operational case differs from that of aircraft engines or grid connected generating turbines. Pipeline turbines may experience extended partial load operation, seasonal intake changes, dusty conditions, variable gas composition, and remote staffing. Dispatch objectives can move setpoints rapidly while compressor protection maintains a separate and faster constraint. Plant historians often span several controls generations and may combine inconsistent time stamps, tags, and calibration histories. Nevertheless, related aviation and energy research remains instructive when its transfer limitations are acknowledged. For example, digital twin work establishes strategies for separating degradation from normal variation, but does not itself establish field reliability improvement for pipeline installations (Hu et al., 2023; Sun et al., 2023).This review considers digital modernisation as a change in the evidence, authority, and assurance surrounding control decisions. Its central argument is that condition monitoring, supervisory optimisation, and security controls add value only when integrated with the physical protection hierarchy. Accordingly, the discussion prioritises design choices, trade offs, and validation criteria over unqualified performance claims.




Figure 1. Conceptual illustration of a digitally instrumented turbine–compressor train in pipeline service. Visualisation is illustrative and is not equipmentspecific engineering evidence.

Aim, objectives and review questions:-

The aim is to critically evaluate how modern digital control architectures can strengthen gas turbine reliability and operational performance in oil and gas pipeline compressor stations, and to derive an implementable, safety aware modernisation framework.

Four objectives guide the review: first, identify failure mechanisms and architectural limitations in aging turbine controls; second, evaluate digital governing, sensing, diagnostic and supervisory approaches for their operational value; third, assess integration challenges created by compressor dynamics, cybersecurity and maintenance governance; and fourth, establish an evidence based validation sequence with measurable reliability and efficiency outcomes.

The analysis asks which functions should remain independent of analytics, how diagnostic models should accommodate variable load and sensor drift, when constrained optimisation can improve performance without eroding surge margin, and what evidence is sufficient to demonstrate a durable benefit after commissioning.

Review methodology and evidence appraisal:-

A structured critical narrative review was undertaken because the question spans controls engineering, turbine health monitoring, pipeline optimisation, and industrial cyber resilience, with dissimilar study designs that preclude defensible statistical pooling. Targeted searches were performed across publisher and journal records using combinations of gas turbine, digital control, compressor station, fault diagnosis, digital twin, supervisory control, model predictive control, reliability, SCADA, and pipeline optimisation. Searches were limited to peer reviewed research or substantive reviews appearing from 2020 through 2025, although the final thirty eligible items fell between 2021 and 2025. DOI landing pages and article metadata were inspected to establish bibliographic identity and relevance.

Inclusion required a direct contribution to at least one of five evidence domains: turbine diagnostics and degradation, turbine controls or digital twins, compressor and pipeline dynamics, station reliability and operational optimisation, or security of industrial monitoring and control. Studies restricted to unrelated machinery, undated promotional claims, inaccessible bibliographic descriptions, and research outside the period were excluded. Aviation applications were eligible only when their transferable method was explicitly distinguished from pipeline field evidence. The supplied gas turbine fault detection article informed the appraisal of classification metrics, not claims about modernisation effectiveness (Amjad et al., 2025).

The synthesis used a domain by domain extraction grid covering physical asset, measured variables, analytic or control method, validation environment, outcome definition, and acknowledged limitations. Evidence was classed as operational case study, experimental or historical data analysis, computational simulation, or conceptual synthesis. Higher interpretive weight was assigned to field data with reproducible fault definitions and meaningful baselines than to isolated model accuracy scores. No pooled percentage improvement is reported because studies differ in turbine class, loading, intervention scope and evaluation window.

The approach is deliberately not represented as an exhaustive database systematic review: database export counts, duplicate screening totals, and independent reviewer agreement were not available and therefore are not invented. This transparency limits claims of completeness but strengthens the distinction between established observations, promising experiments, and recommendations requiring confirmation. Subsequent synthesis tests each technical opportunity against four station level criteria: protective integrity, operational stability, maintainability, and demonstrated economic value.

Technical setting: legacy controls and station failure pathways:-

Traditional turbine control cabinets commonly combine speed governing, temperature limiting, start sequencing, fuel metering, alarm annunciation, and interfaces to machinery protection. Incremental replacement over decades can create multiple data representations and undocumented interlocks. Pneumatic or analog signals may coexist with programmable controllers; process values can reach the historian through slow supervisory scans rather than at the frequency needed to reconstruct vibration, flame instability, or surge events. Control fragility is consequently as much an information problem as a hardware age problem. A retrofit that upgrades displays without rationalising signal provenance leaves this fragility substantially intact.Gas turbine deterioration arises from compressor fouling, erosion, changes in blade clearance, combustion imbalance, sensor degradation, and accessory system faults. These mechanisms modify thermal efficiency, exhaust temperature distribution, vibration, start behaviour, and usable shaft

power, often with overlapping symptoms. De CastroCros et al. (2021) show why data based condition assessment must interpret multivariate behaviour; González Castillo et al. (2021) likewise discuss how faulty engine examples are scarce and difficult to reproduce. A modern controller may detect symptoms more quickly while still failing to isolate a mechanical cause unless temperature, pressure, speed, and maintenance context are reconciled.

The compressor adds a distinct protection problem. A sharp decrease in gas flow can bring the operating point toward surge even when the turbine itself remains within permissible speed and temperature. Anti surge logic typically opens a recirculation valve to protect the compressor at the cost of additional energy expenditure. Modelling by Zhussupova et al. (2024) links valve operation and turbine fuel use, while Meira et al. (2022) demonstrate the value of respecting real gas behaviour and constraints in advanced surge avoidance studies. Protection must respond to transients before higher level economic algorithms complete their calculations.Failure modes also arise at system boundaries: incorrect engineering units, duplicated tags, drifting clocks, unavailable communications, untested restart logic, or remote commands inconsistent with local permissives. When control replacement is treated as software migration alone, these interactions can introduce hazards despite newer components. A defensible modernisationprogramme therefore begins with an asset dependency map, alarm and trip register, signal integrity assessment, controller lifecycle inventory, and explicit acceptance criteria for the turbine compressor package.

Table 1. Controlmodernisation decision matrix: functions, failure risks and assurance requirements.

Function	Legacy limitation	Digital improvement	Essential acceptance test
Speed and fuel governing	Obsolete logic; poor transition records	Versioned controller and timealigned trends	Stable load ramp; safe rollback
Antisurge protection	Slow or opaque recycle response	Independent fast loop with diagnostics	Flow disturbance and actuator fault
Machinery protection	Scattered trip and permissive registers	Audited independent protective logic	Witnessed trip sequence and reset
Remote monitoring	Inconsistent tags and delayed histories	Validated historian, alarms and edge buffer	Lost link and time stamp integrity
Maintenance decision	Calendar based or reactive workflows	Condition alerts with technician feedback	Fault recall and nuisance alarms

Digital modernisation architecture and control authority:-

The proposed architecture separates safety, deterministic regulatory control, supervisory optimisation, and advisory analytics. Hardwired or independently certified trip channels retain authority over overspeed, flame failure, dangerous vibration, and other site specific protective functions. Turbine governing and compressor anti surge control remain within deterministic local systems capable of safe operation during loss of enterprise connectivity. Higher layers may recommend setpoints within approved envelopes but should not bypass protective logic. The separation is functional rather than purely physical: routing, credentials, change approval, and failure behaviour must preserve the same boundaries.

The first upgrade step is trustworthy measurement. Important tags include rotational speed, intake and discharge temperatures, fuel valve position, combustor pressure, shaft vibration, lube oil condition, compressor suction and discharge pressures, recirculation valve position, and operating mode. Sensor quality requires calibration records, range checks, time synchronisation, and flags for substituted or frozen values. CruzManzo et al. (2023) demonstrate why a real time executable twin can help identify sensor faults; their contribution should be interpreted as a diagnostic aid, not a replacement for qualified process instrumentation.

A second layer normalises events and provides contextual historian access. Event sequences should distinguish commanded transitions from emergent trips, correlate turbine and compressor measurements at appropriate temporal resolution, and retain device configuration versions. Edge computing can support local quality checks and compressed summaries, reducing dependence on wide area links. Waqas and Jamil (2024) address monitoring challenges at remote pipeline control stations, although power monitoring interoperability does not directly demonstrate improved turbine control reliability. Data transport is useful only when it makes technical decisions traceable and resilient to network interruption.At the supervisory layer, bounded optimisation can adjust load sharing, operating point selection and planned transitions according to demand, fuel cost and asset condition. Bu et al. (2024) present an economic and tracking control hierarchy for variable pipeline demand; Giraldo et al. (2021)

show that dead time aware predictive control can stabilise gas compression responses in a digital environment. These studies motivate optimisation of operating trajectories rather than continual aggressive pursuit of an ideal static setpoint. Rate limits, ramp limits, surge margin, thermal constraints and operator override remain nonnegotiable design parameters.

Change implementation should follow parallel operation and rollback principles. A new historian or analytic engine can initially observe only, then issue reviewed recommendations, before a narrowly defined supervisory function receives controlled authority. Each transition requires documented tests for sensor failure, lost communications, controller restart, bumpless transfer, emergency shutdown and actuator saturation. Modernisation succeeds when these ordinary failure cases are predictable, not merely when dashboards appear more advanced.




Figure 2. Proposed layered architecture showing independent protection, deterministic local control, audited data pathways and bounded supervisory recommendations. Original synthesis of the review.

Condition monitoring, fault diagnosis and digital twins:-

Digital health monitoring is strongest when physics and operating context constrain the interpretation of data. A compressor wash, ambient temperature change, or intentional load reduction may produce trends resembling degradation. Baseline models therefore need operating mode, inlet conditions, fuel properties and recent maintenance interventions. Hu et al. (2023) combine mechanistic modelling with measurements and adaptive warning thresholds; Luan et al. (2025) address surrogate model monitoring under closed loop identification conditions. Their common implication is that an apparently abnormal residual is meaningful only after uncertainty in normal behaviour has been addressed.

Data driven approaches differ in what they can claim. Principal component methods reveal changes in correlated measurements; supervised classifiers label known faults; recurrent networks describe temporal sequences; and unsupervised detection exposes unfamiliar deviations. Sarwar et al. (2024) combine sensor fusion and neural analysis using an industrial turbine case, whereas Brahimi et al. (2024) use long term failure histories for prognostic monitoring. Miao et al. (2024) explicitly consider changing operating conditions in vibration based anomaly detection. These results support method diversity, but not the proposition that one classifier will generalise to every turbine model or compressor operating envelope.

Assessment must focus on costs of errors. A published example illustrates the danger of accuracy led evaluation: the attached comparative fault detection study reports approximately 0.69 overall accuracy for logistic regression while recording zero recall for its fault class (Amjad et al., 2025). An apparently competitive score therefore failed the operational purpose of detecting actual faults. For turbine systems, useful evaluation should report fault recall by

severity, false alarms per operating month, detection lead time, precision under class imbalance, missed hazardous events, and calibration of confidence under unfamiliar conditions.

Digital twins provide a second line of evidence by comparing predicted and measured performance. Ma et al. (2023) incorporate uncertainty in a data driven twin, while Jin et al. (2024) use combined physical and virtual sensor series for fault isolation. Zhou et al. (2021) link gas path analysis with temporal prognostics, and Talebi (2025) couples thermodynamic reasoning to neural interpretation. Collectively these studies favour hybrid inference, particularly when sparse failure examples restrict direct model training. However, many validation datasets are aviation based or simulated, and they cannot establish pipeline turbine availability without asset specific trials.

A practical diagnostic pipeline should therefore preserve raw evidence, record model version and operating regime, expose the most relevant abnormal measurements, and permit technician rejection of spurious alarms. Maintenance feedback should modify future models only after review; automatic learning from unverified annotations risks encoding recurring mistakes. Diagnostic systems should support engineering decisions, never silently change trip thresholds or protective setpoints.

Integrated turbine compressor optimisation and reliability:-

Turbine efficiency cannot be optimised separately from compressor protection. A governor may hold commanded speed precisely while the compressor loses efficiency through recycling, and a dispatch target that lowers station fuel consumption in steady state may increase stress during repeated ramps. The appropriate objective is therefore a constrained station level function combining delivered gas, fuel use, safe operating margin, component condition and transition cost. This is consistent with the separation between economic planning and short horizon tracking proposed by Bu et al. (2024), rather than treating a single controller as responsible for every decision.

Predictive control has particular appeal because it makes restrictions visible to the optimisation problem. Giraldo et al. (2021) address delay and load disturbances, Meira et al. (2022) examine implementable nonlinear surge avoidance, and Xie and Imani Marrani (2021) analyse robust surge control under uncertainty. Sheng et al. (2023) further emphasise hybrid active and passive protection. The methodological lesson is not that an advanced algorithm supersedes anti surge protection, but that it can plan trajectories which enter the protective region less frequently while the independent layer remains available when model assumptions fail.

Network level studies add another scale. Chen et al. (2022) optimise compressor standby choices against gas delivery reliability, while Xu et al. (2025) examine predictive pressure flow control in hydrogen blended natural gas transmission pipeline networks. Zhou et al. (2024) combine data driven candidate operating schemes with physics basedoptimisation, and Ghilardi et al. (2025) incorporate compressor status and pipe dynamics into a large network model. These findings justify linking local asset condition to dispatch decisions, but network simulations cannot substitute for transient verification of a specific turbine fuel system, torque response, or recycle actuator.

Reliability assessment should extend beyond mean downtime. Turbine availability, successful start probability, protective trip frequency, mean time to diagnose, spare system readiness, and recurrence after repair capture different failure mechanisms. Zhu et al. (2025) demonstrate the importance of allocating maintenance intervention to network delivery consequences. Where redundancy exists, the value of an upgraded turbine depends partly on how it changes station coverage under planned and unplanned outages. Metrics must be normalised for ambient conditions, duty cycle, overhaul exposure and network throughput; otherwise, a favourable annual comparison may reflect easier operating conditions rather than improved control.

A credible commissioning study would compare pre upgrade and post upgrade event logs over adequate equivalent duty, identify concurrent mechanical interventions, and use blinded review of recorded alarms and trips. It would distinguish energy savings caused by a new control law from gains due to washing, overhaul, ambient variation, or revised dispatch. Such causal discipline is essential before extrapolating benefits across a mixed fleet.

Cyber resilience, data governance and human oversight:-

Digital connectivity alters the attack surface of facilities historically protected by limited remote access. Historians, gateways, engineering workstations, vendor diagnostics, and remote dashboards can become paths into operational technology if trust zones are not enforced. Rosa et al. (2021) investigate intrusion and anomaly detection for industrial control systems, while Gaggero et al. (2024) and Benka et al. (2025) assess traffic and anomaly evidence

for cyberphysical monitoring. Their findings support layered detection but do not justify exposing process controllers directly to general purpose networks.

Cyber protection should combine segmented pathways, authenticated remote support, least privilege access, inventory of software versions, offline recovery copies, and controlled engineering changes. Safety functions must remain available when analytics servers are compromised or isolated. Network anomaly alerts should be reconciled with process events because maintenance activity can resemble intrusion, and malicious commands may resemble legitimate operator actions. Equipment security requirements also include tested recovery times, backup compatibility with replacement controllers, and the capacity to restore verified setpoints after a disruptive event.
The human interface deserves equal attention. Too many poorly prioritised warnings can degrade situational awareness; overconfident algorithms can encourage premature intervention. A modernised console should present equipment state, the evidence behind recommendations, current constraints, and explicit approval or rejection controls. Every model driven suggestion requires an audit trail identifying data quality, model version, operator decision, and observed outcome. In this arrangement, automation improves the quality of human judgment rather than concealing uncertainty behind a numerical health score.

Critical synthesis and proposed validation framework:-
Across the evidence base, three claims are comparatively well supported. First, multivariate monitoring improves diagnostic visibility relative to isolated threshold alarms when sensor integrity and operating context are controlled (Liu et al., 2024; Sarwar et al., 2024). Second, constrained supervisory control can improve simulated or case specific compressor trajectories under demand changes, provided safety restrictions are explicit (Giraldo et al., 2021; Bu et al., 2024). Third, pipeline reliability depends on dispatch and redundancy beyond an individual turbine package (Chen et al., 2022; Ghilardi et al., 2025). These propositions describe mechanisms, not a universal percentage reduction in failures.

The weakest link is evidence transfer. Accuracy demonstrated on a turbofan dataset, availability estimated from historical records, and fuel reduction achieved in a network optimisation case have different denominators and causal interpretations. Neither should be presented as proof of identical gains for an older pipeline turbine. Field work must account for sensor placement, unrecorded interventions, turbine age, controller vendor, ambient conditions, variable flow demand and operator behaviour. In particular, class imbalance can make general accuracy attractive even when important faults are missed, as demonstrated by the source study used for methodological contrast (Amjad et al., 2025).

A staged validation framework follows logically. Stage one audits physical interfaces, protective functions, instruments and baseline failure data. Stage two installs time synchronised acquisition and evaluates diagnostics without changing control authority. Stage three tests supervisory proposals against a validated simulator and retrospective operating records. Stage four executes witnessed hardware in the loop tests, including sensor bias, stuck actuator, delayed communications, rapid demand change and protective shutdown. Stage five permits restricted live optimisation with predefined rollback triggers and independent safety oversight. Stage six reviews longitudinal outcomes against equivalent duty and publishes an explicit uncertainty assessment.

Acceptance gates should be tied to evidence rather than vendor claims. An alarm model should demonstrate meaningful fault class recall and manageable nuisance rate; a controller should maintain minimum surge margin and avoid worsening trip recovery; an architecture should recover safely after lost communications; and reliability claims should survive comparison with a credible pre intervention baseline. Performance improvements that fail any protective integrity gate should not progress to deployment. This ordering gives the organisation a measurable path from technical feasibility to operational assurance.

A first source of uncertainty is the time resolution of historical evidence. Historian samples can conceal brief combustor excursions or actuator oscillations, while vibration records may miss preceding dispatch actions. Data architecture should follow investigation requirements, not bandwidth alone. Event reconstruction benefits from synchronised controller states, alarm sequences, operating modes, sensor validation flags, and maintenance notes. Otherwise, an apparently sophisticated digital twin may rest on incomplete causal information, undermining both its diagnostic conclusions and its value in root cause investigations.

A second issue is the distinction between controller replacement and control strategy improvement. Migrating a proven speed governor to a newer processor could increase maintainability and availability of replacement

components without changing efficiency. Conversely, implementing a new predictive strategy might reduce consumption during changing demand but introduce additional engineering, validation, and training obligations. They require different comparators. Hardware migration should be assessed through failures, spares, and restoration time. For control law modification, stability margins, limit handling, energy consumption, and transient performance deserve emphasis. Combining changes in one comparison obscures attribution.

A third issue concerns alarm fatigue and the governance of diagnosis. A sensitive anomaly detector will generate warnings from normal but infrequent operating states unless its baseline reflects genuine process diversity. An alert costs more than acknowledgement: investigation may require field access, monitoring, shutdown, or deferred work. Alarm evaluation should therefore include engineering effort and avoided consequential failures, not classification statistics alone. High consequence protective events should be addressed through established independent safeguards regardless of the apparent confidence of an analytic model. Human review remains essential.

Economic performance requires a consistent system boundary. Lower fuel use at one train may not save energy network wide if another compressor must compensate, if additional recirculation is needed, or if linepack and delivery timing change. Evaluations should report fuel per delivered gas, compression duty, ambient conditions, and standby capacity. Dispatch decisions should also account for asset condition: an efficient operating point can be undesirable if it accelerates degradation before a constrained maintenance window. Business cases should compare operating scenarios, uncertainty, and recipients of benefits.

Fleet adoption requires explicit technical gates. A successful pilot on a newly overhauled turbine may not transfer to older machines. Replication should proceed across varied loads, ambient conditions, controller families, and maintenance histories, using the same definitions of nuisance alarm, forced outage, degraded operation, and recovered function. Documenting unsuccessful trials, recalibration, and rollback would strengthen evidence. This discipline creates a feedback loop between operations and research rather than a sequence of disconnected technology demonstrations.For each deployment, operators should retain verified configuration baselines and a signed engineering decision, identifying who accepted residual risk, which conditions justified authorisation, and when the decision requires formal independent reassessment.

Table 2. Evidencetodecision matrix for staged commissioning. Metrics are recommendations, not pooled empirical results.

Evidence domain	Strongest available contribution	Unresolved concern	Validation gate
Turbine diagnostics	Field telemetry and hybrid fault inference	Rare fault sensitivity; transfer bias	Recall, lead time and false alarms
Digital twins	Modeaware residuals and sensor checking	Model drift after maintenance	Unseen regimes and sensor bias
Supervisory control	Constrained transient optimisation	Interaction with fast surge protection	Hardwareintheloop fault trials
Pipeline operations	Networkwide dispatch and standby models	Actual package dynamics differ	Delivery reliability and duty matching
Cyber and recovery	Monitoring of industrial network anomalies	Privilege misuse and recovery gaps	Isolated operation and restore tests

Research gaps and future directions:-

Several gaps prevent straightforward scale up. First, most published predictive studies do not include long, independently annotated records from turbine driven transmission compressor packages. Shared test protocols should report asset class, operating regime, fault severity, sensor uncertainty and the time between warning and required intervention. Second, diagnostics and control are usually studied separately, leaving uncertain whether a health based speed recommendation destabilises surge protection during an abrupt dispatch change. Joint turbine compressor experiments with independent trip oversight are therefore necessary.

Third, current digital twin results need stronger out of distribution testing. A model calibrated after overhaul may fail following seasonal gas composition changes, calibration drift or controller firmware replacement. Future work should compare physics constrained residuals, statistical confidence and technician verified evidence, and document criteria for model retraining (Hu et al., 2023; Luan et al., 2025). Fourth, cyber recovery and control recovery are

seldom evaluated together, despite their operational interdependence. Fifth, environmental claims require metered fuel consumption and emissions normalised to delivered gas and duty rather than inferred savings from isolated laboratory performance.

Finally, the economics of modernisation remain underreported. Lifecycle studies should include migration downtime, engineering validation, instrument maintenance, software licensing, operator training, cyber maintenance, and the opportunity cost of delayed upgrades. A transparent multicriteria comparison would allow asset owners to prioritise retrofits according to network criticality instead of equipment age alone.

Practical and managerial implications:-

For operating companies, the recommended starting point is a risk ranked brownfield survey rather than immediate replacement of the entire control platform. Rank units by delivery criticality, recurring trips, unavailable spares, instrumentation gaps, controller support status, and restart history. Establish a frozen baseline before major overhaul and collect common event definitions across stations. A modest instrumentation and historian improvement may provide greater immediate value than an advanced classifier operating on unreliable signals.

Engineering teams should develop an interface control document covering turbine, compressor, station supervisory systems, emergency shutdown, remote dispatch and vendor access. Before granting higher level control authority, require witnessed tests for anti surgebehaviour, fuel limits, load rejection, alarm handling, operator override and restoration from backup. Decision makers should specify operational outcomes: fewer avoidable shutdowns, shorter fault diagnosis, better documented start reliability, reduced recycle energy, and traceable maintenance interventions. Each claim must state the measurement window and uncertainty.

At policy level, asset assurance procedures should address model versioning, cybersecurity patch management, independent review of protective settings, and retention of evidence for consequential automatic recommendations. This approach allows innovation without treating safety critical equipment as a continuously changing software experiment.

Limitations of the Review:-

This synthesis draws on thirty DOI identifiable papers with different research designs; it is not a quantitative meta analysis and does not estimate a single effect size. Some closely related turbine health studies examine aircraft rather than pipeline installations, and their results are used to assess transferable mechanisms rather than claimed field outcomes. The review relies on public publication information rather than access to proprietary control configurations, full incident archives, or manufacturer test records. It also does not conduct original turbine experiments or inspect live cybersecurity systems. Consequently, the proposed framework is a design and validation recommendation that requires site specific engineering verification before use.

Conclusion:-

Digital modernisation of gas turbine controls can improve the reliability and operational performance of pipeline compression infrastructure when it is engineered as a coherent station level change. The strongest route is to protect independent shutdown and anti surge functions, strengthen measurement provenance, make governing performance observable, and then introduce bounded diagnostic and optimisation services. Evidence from recent turbine health and pipeline control research establishes plausible benefits but not universal field improvement rates. Reliable implementation requires fault sensitive evaluation, staged authority, cyber recoverability, trained operators, and comparison against equivalent operating duty. Future research must close the gap between convincing analytic demonstrations and verifiable long term outcomes in turbine driven pipeline stations.

References:-

1. Amjad, M. H. H., Chowdhury, B. R., Reza, S. A., et al. (2025). AIpowered fault detection in gas turbine engines: Enhancing predictive maintenance in the U.S. energy sector. Journal of Ecohumanism, 4(4), 658–678. https://doi.org/10.62754/joe.v4i4.6773
2. Benka, D., Horváth, D., Špendla, L., Gašpar, G., and Strémy, M. (2025). Machine learningbased detection of anomalies, intrusions, and threats in industrial control systems. IEEE Access, 13, 12502–12514. https://doi.org/10.1109/ACCESS.2025.3530902

3. Brahimi, L., Hadroug, N., Iratni, A., Hafaifa, A., and Colak, I. (2024). Advancing predictive maintenance for gas turbines: An intelligent monitoring approach with ANFIS, LSTM, and reliability analysis. Computers & Industrial Engineering, 191, 110094. https://doi.org/10.1016/j.cie.2024.110094
4. Bu, Y., Swartz, C. L. E., and Wu, C. (2024). A twolevel MPC method for the operation of a gas pipeline system under demand variation. Computers & Chemical Engineering, 183, 108597. https://doi.org/10.1016/j.compchemeng.2024.108597
5. Chen, Q., Zuo, L., Wu, C., Li, Y., Hua, K., Mehrtash, M., and Cao, Y. (2022). Optimization of compressor standby schemes for gas transmission pipeline systems based on gas delivery reliability. Reliability Engineering & System Safety, 221, 108351. https://doi.org/10.1016/j.ress.2022.108351
6. CruzManzo, S., Panov, V., and Bingham, C. (2023). Gas turbine sensor fault diagnostic system in a realtime executable digitaltwin. Journal of the Global Power and Propulsion Society, 7, 85–94. https://doi.org/10.33737/jgpps/159781
7. de CastroCros, M., Velasco, M., and Angulo, C. (2021). Machinelearningbased condition assessment of gas turbines: A review. Energies, 14(24), 8468. https://doi.org/10.3390/en14248468
8. Gaggero, G., Armellin, A., Portomauro, G., and Marchese, M. (2024). Industrial control system–anomaly detection dataset (ICSADD) for cyberphysical security monitoring in smart industry environments. IEEE Access, 12, 64140–64149. https://doi.org/10.1109/ACCESS.2024.3395991
9. Ghilardi, L. M. P., Casella, F., Barbati, D., Palazzo, R., and Martelli, E. (2025). A detailed MILP model and an ad hoc decomposition algorithm for the operational optimization of gas transport networks. Computers & Chemical Engineering, 195, 109006. https://doi.org/10.1016/j.compchemeng.2025.109006
10. Giraldo, S. A. C., Supelano, R. C., d'Avila, T. C., et al. (2021). Model predictive control with deadtime compensation applied to a gas compression system. Journal of Petroleum Science and Engineering, 203, 108580. https://doi.org/10.1016/j.petrol.2021.108580
11. González Castillo, I., Loboda, I., and Pérez Ruiz, J. L. (2021). Datadriven models for gas turbine online diagnosis. Machines, 9(12), 372. https://doi.org/10.3390/machines9120372
12. Hu, M., He, Y., Lin, X., et al. (2023). Digital twin model of gas turbine and its application in warning of performance fault. Chinese Journal of Aeronautics, 36(3), 449–470. https://doi.org/10.1016/j.cja.2022.07.021
13. Jin, Z., Liu, J., Xu, M., Miao, H., and Song, Z. (2024). An enhanced digital twindriven fault detection and isolation method based on sensor series imaging mechanism for gas turbine engine. Applied Thermal Engineering, 257, 124308. https://doi.org/10.1016/j.applthermaleng.2024.124308
14. Liu, X., Chen, Y., Xiong, L., Wang, J., Luo, C., Zhang, L., and Wang, K. (2024). Intelligent fault diagnosis methods toward gas turbine: A review. Chinese Journal of Aeronautics, 37(4), 93–120. https://doi.org/10.1016/j.cja.2023.09.024
15. Luan, J., Li, S., Cao, Y., and Gu, C. (2025). Application of a surrogate model for condition monitoring of a digital twin gas turbine. Applied Mathematical Modelling, 137, 115683. https://doi.org/10.1016/j.apm.2024.115683
16. Ma, Y., Zhu, X., Lu, J., Yang, P., and Sun, J. (2023). Construction of datadriven performance digital twin for a realworld gas turbine anomaly detection considering uncertainty. Sensors, 23(15), 6660. https://doi.org/10.3390/s23156660
17. Meira, R. L., Martins, M. A. F., Kalid, R. A., and Costa, G. M. N. (2022). Implementable MPCbased surge avoidance nonlinear control strategies for nonideally modeled natural gas compression systems. Journal of Natural Gas Science and Engineering, 102, 104573. https://doi.org/10.1016/j.jngse.2022.104573
18. Miao, D., Feng, K., Xiao, Y., Li, Z., and Gao, J. (2024). Gas turbine anomaly detection under timevarying operation conditions based on spectra alignment and selfadaptive normalization. Sensors, 24(3), 941. https://doi.org/10.3390/s24030941
19. Rosa, L., Cruz, T., Freitas, M. B., Quitério, P., Henriques, J., Caldeira, F., Monteiro, E., and Simões, P. (2021). Intrusion and anomaly detection for the nextgeneration of industrial automation and control systems. Future Generation Computer Systems, 119, 50–67. https://doi.org/10.1016/j.future.2021.01.033
20. Sarwar, U., Muhammad, M., Mokhtar, A. A., Wassan, R. K., Behrani, P., and Kaka, S. (2024). Hybrid intelligence for enhanced fault detection and diagnosis for industrial gas turbine engine. Results in Engineering, 21, 101841. https://doi.org/10.1016/j.rineng.2024.101841
21. Sheng, H., Chen, Q., Zhang, J., et al. (2023). A highsafety active/passive hybrid control approach for compressor surge based on nonlinear model predictive control. Chinese Journal of Aeronautics, 36(1), 396–412. https://doi.org/10.1016/j.cja.2022.08.021
22. Sun, J., Yan, Z., Han, Y., Zhu, X., and Yang, C. (2023). Deep learning framework for gas turbine performance digital twin and degradation prognostics from airline operator perspective. Reliability Engineering & System Safety, 238, 109404. https://doi.org/10.1016/j.ress.2023.109404

23. Talebi, S. S. (2025). Fault diagnosis of micro gas turbine using a hybrid scheme of thermodynamic analysis and artificial neural network. Heliyon, 11(10), e43378. https://doi.org/10.1016/j.heliyon.2025.e43378
24. Waqas, M., and Jamil, M. (2024). Smart IoT SCADA system for hybrid power monitoring in remote natural gas pipeline control stations. Electronics, 13(16), 3235. https://doi.org/10.3390/electronics13163235
25. Xie, C., and Imani Marrani, H. (2021). Design of a robust LMIbased model predictive control method for surge instability in interconnected compressor systems in the presence of uncertainty and disturbance. Systems Science & Control Engineering, 9(1), 358–368. https://doi.org/10.1080/21642583.2021.1899999
26. Xu, Q., Yu, X., Sun, Y., Zhu, Z., and Zhang, X. (2025). Modelling and safe control of hydrogen doped natural gas pipeline using pressureflow dual control methodology. Computers & Chemical Engineering, 199, 109161. https://doi.org/10.1016/j.compchemeng.2025.109161
27. Zhou, H., Ying, Y., et al. (2021). Longshort term memory and gas path analysis based gas turbine fault diagnosis and prognosis. Advances in Mechanical Engineering, 13. https://doi.org/10.1177/16878140211037767
28. Zhou, J., Qin, C., Fu, T., Liu, S., Liang, G., Li, C., and Hong, B. (2024). Automatic response framework for large complex natural gas pipeline operation optimization based on datamechanism hybriddriven. Energy, 307, 132610. https://doi.org/10.1016/j.energy.2024.132610
29. Zhu, W., Hou, L., and Su, H. (2025). Centrifugal compressor overhaul cycle optimization based on reliability allocation. Journal of Pipeline Systems Engineering and Practice, 16(4). https://doi.org/10.1061/JPSEA2.PSENG1691
30. Zhussupova, D., Otelbaev, M., and Burgumbayeva, S. (2024). Modeling gas compressor station operation to minimize fuel costs for surge zone protection. International Journal of Rotating Machinery, 2024, 5560308. https://doi.org/10.1155/2024/5560308